

## DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanaiya Chownk, Opposite Khalsa sr. sec. school, Faridkot  
dwtlfdk@gmail.com

To,

THE BLOOMINGDALE SCHOOL ,KOTKAPURA ,FARIDKOT  
THE BLOOMINGDALE SCHOOL ,KOTKAPURA ,FARIDKOT


No.: DWTL/FDK/2526/00072 Dated : 28/05/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 55/2024 Dated: 27/05/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 27/05/2025. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Faridkot

D/A : Test Report



**Authorized Signatory**  
**For, District water Testing Laboratory**  
**Faridkot**

# DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanaiya Chownk, Opposite Khalsa sr. sec. school, Faridkot  
dwtlfdk@gmail.com



TC-13893

## TEST REPORT

Name & Address of Customer : <b>THE BLOOMINGDALE SCHOOL ,KOTKAPURA ,FARIDKOT THE BLOOMINGDALE SCHOOL ,KOTKAPURA ,FARIDKOT</b>		Customer Reference No.	No : 55/2024 Dated : 27/05/2025			
		Sample Submitted by	VARINDER SINGH			
		Date of Sample Receipt	27/05/2025			
		Analysis Starting Date	27/05/2025			
		Analysis completion Date	28/05/2025			
Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>				
ULR No.:	TC10394250000222F	Sample Type :	Treated Water			
Test Report No.:	DWTL/FDK/2526/00072	Date of Issue :	28/05/2025			
Registration no.:	DWTL/FDK/REG2526/00252	Condition of Sample :	Sealed			
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles			
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	THE BLOOMINGDALE SCHOOL ,KOTKAPURA ,FARIDKOT / NA			
Village :	Not Mentioned	Habitation :	Not Mentioned			
Block:	Kot Kupura	District :	Faridkot			
Latitude :	Not Mentioned	Longitude:	Not Mentioned			
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.86@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	210	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	60	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	112	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	17.6	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	16.5	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	50	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Ashish Kumar  
Sr. Chemist  
Authorized Signatory  
For, District water Testing Laboratory  
Faridkot

----- End of the Test Report -----